



| | | |
|---------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|------------------------------------|
| Materials/Finishes: | Pre-Galvanized (310NFG) | Plastic Coated 1/2" - 8" (310NFPC) |
| Variants: | Pre-Galvanized, 3/16" Felt-lined: 1/2" - 8" (310NFPL) | |
| Service: | Designed for the suspension of non-insulated stationary pipe lines. Typically used as a pipe support for sprinkler piping. Hanger is manufactured to use minimum rod sizes permitted by NFPA. The plastic coated band hanger protects the pipe from the steel surface of the hanger and is designed to reduce noise, vibration and prevents electrolysis between pipe and the hanger. | |
| Approvals: | U.L. - U.L.C. listed and FM approved (2-1/2"-8"). Complies with Manufacturers' Standardization Society MSS SP-58 and SP-69 (Type# 10). | |
| Ordering: | Specify figure number, finish and pipe size. | |
| Notes: | For sizes 1/2" - 2", please refer to 310G submittal. | |

| PIPE SIZE | PIPE OD | A | B | C | E | F | G | WGT EACH (lbs) | MAX REC LOAD (lbs) |
|-----------|---------|-----|---------|---------|-------|-------|--------|----------------|--------------------|
| 2-1/2 | 2.875 | 3/8 | 3-7/8 | 5-3/8 | 3-1/8 | 1-3/8 | 7/8 | 0.24 | 600 |
| 3 | 3.500 | 3/8 | 4-1/2 | 6-1/4 | 3-5/8 | 1-5/8 | 7/8 | 0.28 | 600 |
| 3-1/2 | 4.000 | 3/8 | 4-7/8 | 6-7/8 | 4 | 1-3/4 | 7/8 | 0.32 | 600 |
| 4 | 4.500 | 3/8 | 5 | 7-1/4 | 4-1/8 | 1-5/8 | 7/8 | 0.32 | 750 |
| 5 | 5.563 | 1/2 | 5-3/4 | 8-1/2 | 4-1/4 | 1-7/8 | 1-1/16 | 0.62 | 1000 |
| 6 | 6.625 | 1/2 | 6-3/4 | 10-1/8 | 5-1/8 | 2-1/8 | 1-1/16 | 0.65 | 1250 |
| 8 | 8.625 | 1/2 | 7-7/8 | 12-1/4 | 7 | 2-3/8 | 1-1/16 | 1.00 | 1250 |
| 10 | 10.750 | 1/2 | 9-11/16 | 15-1/16 | 8-5/8 | 3-1/4 | 1-1/16 | 1.675 | 1250 |

| PROJECT INFORMATION | APPROVAL STAMP |
|---------------------------------------------------|----------------|
| Project: | Notes: |
| Address: | |
| Contractor: | |
| Engineer: | |
| Date: | |
| Approved Approved as Noted Not Approved | |